




CONDITION 1




CONDITION 2



CONDITION 3




CONDITION 4




CONDITION 5


(@ ENGINEERS DISC)




CONDITION 6




CONDITION 7



CONDITION 8



ANCHOR REQ'D. FOR VALVES 12" OR LARGER



TYPICAL SECTION THRU THRUST BLOCK

THRUST BLOCK BEARING AREA IN SQ. FT.								
PIPE SIZE	CONDITION							
	1	2	3	4	5	6	7	8
4	2.6	3.3	2.6	1.3	1.3	2.0	3.3	2.6
6	4.6	6.5	3.9	2.0	2.6	3.3	6.5	4.6
8	7.8	11.0	5.9	3.3	3.9	5.9	11.0	7.8
10	12.4	17.5	9.8	5.2	6.5	9.1	17.5	12.4
12	17.5	24.8	13.6	7.8	9.1	12.3	24.8	17.5
14	24.0	33.8	18.2	9.7	12.3	16.9	33.8	24.0
16	31.1	44.0	23.8	12.7	15.5	23.2	44.0	31.1
20	48.6	68.8	37.2	19.8	24.2	36.3	68.8	48.6
24	89.8	90.1	48.8	24.9				

NOTES:

1. ALL THRUST BLOCK BEARING FACES SHALL BE POURED AGAINST UNDISTURBED SOIL OR APPROVED COMPACTED BACKFILL.
2. CONCRETE SHALL BE CLASS 6.0-B-3000.
3. ALL THRUST BLOCK SIDES SHALL BE FORMED.
4. CALCULATED ON 225 LB. TEST PRESSURE AND ALLOWABLE BEARING PRESSURE OF 200 LBS. PER SQUARE FEET.
5. IN POORER SOILS SPECIAL DESIGN IS REQUIRED.

TYPICAL PIPE THRUST BLOCKING

N.T.S

HEBER CITY
STANDARD DRAWING
WATER-2