


NOTES:
 1. FIRE HYDRANT DRAINS SHALL NOT BE CONNECTED TO, OR LOCATED WITHIN, 10 FEET OF SANITARY SEWERS. WHERE POSSIBLE, HYDRANT DRAINS SHALL NOT BE LOCATED WITHIN 10 FEET OF STORM DRAINS.

V:\ENGR\Stus\StusSpec\StusSpec 2019\Drawg Files\WATER-1.dwg - Fire Hydrants - 2/06/2019 12:25pm - r.tunk

HORROCKS ENGINEERS
 728 WEST 100 SOUTH #2
 HEBER CITY, UTAH 84032
 (435) 654-2226

DATE:	FEBRUARY 2019
SCALE:	N.T.S.
	75 NORTH MAIN STREET HEBER CITY, UTAH 84032 (435) 654-0757



HEBER CITY STANDARD DRAWING
 WATER-1