



| TABLE 1 | | | | |
|-------------------|------------------------|----------------------|----------------------------------|--------------|
| SERVICE LINE SIZE | MINIMUM METER BOX SIZE | BOX MODEL | LID / FRAME MODEL | COMMENTS |
| 1" MINIMUM | 21" x 18" | 330IS2118FABS000646N | DFW18MR-1BF1 SML IRR / 700098-1 | NEW SERVICES |
| 1.5" | 27" x 24" | 500IS2724FAB000666N | DFW18MR-1BF1 SML IRR / 700098-1 | NEW SERVICES |
| 2" | 36" x 36" | 550IS3636FAB000666N | SAME AS ABOVE w/ 790138 EXP RING | NEW SERVICES |

NOTE 1: FOR LARGER SIZES CONTACT PUBLIC WORKS FOR REQUIREMENTS




SECTION VIEW

4 INCH SLEEVE 10 INCHES BELOW SIDEWALK SURFACE, EXTENDED A MINIMUM OF 6 INCHES PAST THE SIDEWALK ON BOTH SIDES & CAPPED



SECTION




NOTES:

1. ALL COMPONENTS SHOWN TO BE FURNISHED AND INSTALLED BY DEVELOPER AND CONFORM TO AWWA C800.
2. STAINLESS STEEL STIFFENERS ON ALL POLY CONNECTIONS.
3. METER BOXES ALLOWED WITHIN DRIVEWAY ZONE ONLY WITH PRIOR APPROVAL FROM PUBLIC WORKS DIRECTOR.
4. WHEN METER BOXES ARE INSTALLED WITHIN DRIVEWAY ZONES OR WITHIN OTHER PAVED SURFACES, DIFFERENT TRAFFIC RATED LIDS & FRAMES MAY BE REQUIRED PER THE DIRECTION OF THE PUBLIC WORKS DIRECTOR.
5. IRRIGATION METER CAN TO BE LOCATED IN THE MIDDLE OF THE PLANTER STRIP OR BETWEEN SIDEWALK AND PROPERTY LINE (FOR COMBINATION SIDEWALK) OR AS DIRECTED BY ENGINEER. 4" SLEEVE REQUIRED ON ALL INSTALLATIONS INCLUDING EXISTING SIDEWALK.
6. IRRIGATION SERVICE SHOULD CONNECT DIRECTLY TO THE MAIN LINE AND NOT "TEE" OFF OF SERVICE LINES.
7. METER CAN SHALL BE COMPLETELY BACKFILLED WITH COMPACTED 3" MINUS GRANULAR MATERIAL FROM TOP TO BOTTOM.
8. BEDDING OF ALL PIPE SHALL CONFORM TO HEBER CITY BEDDING STANDARDS FOR CULINARY WATER.
9. METER FEE WILL BE ASSESSED WITH BUILDING PERMIT OR AT TIME OF METER INSTALLATION.

IRRIGATION SERVICE - ONE LOT

| | |
|--|-----------|
| DATE: | JUNE 2021 |
| SCALE: | N.T.S. |
| 75 NORTH MAIN STREET HEBER CITY, UTAH 84032 (435) 654-0757 | |



HEBER CITY
IRRIGATION-1B